

Nanoose # 3 - Well Data - Depth 156.5 ft / 47.7 m

2004	Average Capacity (m ³ /min)	Discharge pressure (psi)	Static level (ft)	Static level (m)	Pumping level (ft)	Pumping Level (m)	Drawdown (m)	Meter reading (m ³)	Monthly Consumption (m ³)	Hour Meter	Total Hours	Water over pump			
												Level (m)	Level Low	Level Critical	
Jan-04	0.240	85	144	43.89	151	46.02	2.13	162620	2303	3082.3	159.7	2.18	no	no	
Feb-04	0.244	85	144	43.89	151	46.02	2.13	164923	1947	3242	133	2.18	no	no	
Mar-04	0.246	90	144	43.89	150	45.72	1.83	166870	2672	3375	181.3	2.48	no	no	
Apr-04	0.239	84	144	43.89	150	45.72	1.83	169542	2992	3556.3	208.8	2.48	no	no	
May-04	0.223	84	144.5	44.04	151	46.02	1.98	172534	1610	3765.1	120.5	2.18	no	no	
Jun-04	1.677	off	off	#VALUE!	off	#VALUE!	#VALUE!	174144	493	3885.6	4.9	#VALUE!	#VALUE!	#VALUE!	
Jul-04	#DIV/0!	off	off	#VALUE!	off	#VALUE!	#VALUE!	493	86	3890.5	0	#VALUE!	#VALUE!	#VALUE!	
Aug-04	#DIV/0!	off	off	#VALUE!	off	#VALUE!	#VALUE!	579	2034	3890.5	0	#VALUE!	#VALUE!	#VALUE!	
Sep-04	#DIV/0!	64	n/a	#VALUE!	n/a	#VALUE!	#VALUE!	2613	1882	3890.5	0	#VALUE!	#VALUE!	#VALUE!	
Oct-04	0.181	70	n/a	#VALUE!	n/a	#VALUE!	#VALUE!	4495	1921	105.8	176.9	#VALUE!	#VALUE!	#VALUE!	
Nov-04	0.166	68	n/a	#VALUE!	n/a	#VALUE!	#VALUE!	6416	1509	282.7	151.3	#VALUE!	#VALUE!	#VALUE!	
Dec-04	0.139	65	141.7	43.19	148.5	45.26	2.07	7925	1264	434	151.1	2.94	no	no	
Jan-05	n/a	n/a	n/a	n/a	n/a	n/a	n/a	9189	n/a	585.1	n/a				
Ave. Cap.	0.210														

Well Data Summary * #DIV/0! or #VALUE! = insufficient data to complete formula

Static Level	
Minimum	43.19
Maximum	44.04
Average	43.80

Pumping Level	
Minimum	45.26
Maximum	46.02
Average	45.80

Drawdown	
Minimum	1.83
Maximum	2.13
Average	2.00

Consumption	
Minimum	86
Maximum	2992
Average	1726.1
Total	20713

Total Hours	
Minimum	0
Maximum	208.8
Average	107.3
Total	1287.5

