

Nanoose # 4 - Well Data - Depth - 174 ft / 53 m

2004	Average Capacity (m³/min)	Discharge pressure (psi)	Static level (ft)	Static level (m)	Pumping level (ft)	Pumping Level (m)	Drawdown (m)	Meter reading (m³)	Monthly Consumption (m³)	Hour Meter	Total Hours	Water over pump		
												Level (m)	Level Low	Level Critical
Jan-04	0.289	44	134	40.84	147	44.81	3.96	586871	2765	22163.2	159.3	8.19	no	no
Feb-04	0.289	22	132.5	40.39	148	45.11	4.72	589636	2316	22322.5	133.4	7.89	no	no
Mar-04	0.297	32	135.5	41.30	149	45.42	4.11	591952	3220	22455.9	180.6	7.58	no	no
Apr-04	0.300	22	137	41.76	146	44.50	2.74	595172	3745	22636.5	208.3	8.50	no	no
May-04	0.309	22	135.5	41.30	148	45.11	3.81	598917	6853	22844.8	369.4	7.89	no	no
Jun-04	0.306	24	140	42.67	153	46.63	3.96	605770	8222	23214.2	448	6.37	no	no
Jul-04	0.301	26	147	44.81	155	47.24	2.44	613992	10034	23662.2	555.9	5.76	no	no
Aug-04	0.301	28	146	44.50	161	49.07	4.57	624026	8583	24218.1	475.9	3.93	no	no
Sep-04	0.313	28	141	42.98	155	47.24	4.27	632609	4521	24694	240.7	5.76	no	no
Oct-04	0.320	32	137	41.76	147	44.81	3.05	637130	3380	24934.7	175.8	8.19	no	no
Nov-04	0.325	26	135	41.15	150	45.72	4.57	640510	2955	25110.5	151.4	7.28	no	no
Dec-04	0.334	30	136.5	41.61	148	45.11	3.51	643465	3001	25261.9	149.6	7.89	no	no
Jan-05	n/a	n/a	n/a	n/a	n/a	n/a	n/a	646466	n/a	25411.5	n/a			
Ave. Cap.	0.307													

Well Data Summary * #DIV/0! or #VALUE! = insufficient data to complete formula

Static Level	
Minimum	40.39
Maximum	44.81
Average	42.09

Pumping Level	
Minimum	44.50
Maximum	49.07
Average	45.90

Drawdown	
Minimum	2.44
Maximum	4.72
Average	3.81

Consumption	
Minimum	2316
Maximum	10034
Average	4966.3
Total	59595

Total Hours	
Minimum	133.4
Maximum	555.9
Average	270.7
Total	3248.3

