

### West Bay # 3 - Well Data - Depth 214 ft / 65.3 m

2000	Average Capacity (m <sup>3</sup> /min)	Discharge pressure (psi)	Static level (ft)	Static level (m)	Pumping level (ft)	Pumping Level (m)	Drawdown n (m)	Meter reading (m <sup>3</sup> )	Monthly Consumption (m <sup>3</sup> )	Hour Meter	Total Hours
Jan-00	0.753			0.00		0.00	0.00		10707		237
Feb-00	0.753			0.00		0.00	0.00		4626.4		102.4
Mar-00	0.753			0.00		0.00	0.00		5335.7		118.1
Apr-00	0.753			0.00		0.00	0.00		7752.8		171.6
May-00	0.753			0.00		0.00	0.00		7147.4		158.2
Jun-00	0.753			0.00		0.00	0.00		10716.7		237.2
Jul-00	0.753			0.00		0.00	0.00		16038.9		355
Aug-00	0.753			0.00		0.00	0.00	213439	14954.6	9241.1	331
Sep-00	0.749	185	166	50.60	182	55.47	4.88	225867	12428	9517.1	276.6
Oct-00	0.753	195	165	50.29	181	55.17	4.88	233705	7838	9691.2	173.5
Nov-00	0.757	188	154	46.94	175	53.34	6.40	240189	6484	9833.9	142.7
Dec-00	0.443	185	157	47.85	175	53.34	5.49	202277	4228	11636.1	159.1
Jan-01	n/a	n/a	n/a	n/a	n/a	n/a	n/a		n/a		n/a

#### Well Data Summary

Static Level	
Minimum	0.00
Maximum	50.60
Average	16.31

Pumping Level	
Minimum	0.00
Maximum	55.47
Average	18.11

Drawdown	
Minimum	0.00
Maximum	6.40
Average	1.80

Consumption	
Minimum	4228
Maximum	16038.9
Average	9021.5
Total	108257.5

Total Hours	
Minimum	102.4
Maximum	355
Average	205.2
Total	2462.4

